



- NOTES:**
- 1) PIPING TO BE BRASS AND COPPER TUBING. METER INLET AND OUTLET TO BE EQUIPPED WITH FLANGED BALL ANGLE METER VALVES.
 - 2) CUSTOM SETTERS SHALL BE EQUIPPED WITH STANDARD LOW BYPASS WITH BALL VALVE AND PADLOCK WINGS.
 - 3) CUSTOM SETTERS SHALL BE AS MANUFACTURED BY MUELLER, FORD, AY MCDONALD, OR APPROVED EQUAL.
 - 4) ALL COMMERCIAL APPLICATIONS REQUIRE A SEPARATE ABOVE GROUND BACKFLOW PREVENTER.
 - 5) CUSTOM SETTER SHALL BE INSTALLED SUCH THAT METER REGISTER IS LOCATED 5 TO 8 INCHES BELOW METER BOX COVER.

NOTE:
TO ENSURE POSITIVE DRAINAGE, THE VAULT SHALL HAVE AN OPEN BOTTOM TO ALLOW DRAINAGE THROUGH STONE.

DIMENSIONS (INCHES)	
A	B
18 3/4"	30 3/8"



STANDARD 1 1/2" & 2" METER INSTALLATION & VAULT

DETAIL No.
06000.02
SHEET 1 OF 1