



- NOTES:**
1. ALL PIPING AND FITTINGS, IN THE MANHOLE, SHALL BE BRASS.
 2. CORPORATION STOP SHALL BE LOCATED IN THE TOP OF MAIN.
 3. MANHOLE STEPS SHALL BE PLACED 16" O.C. WHEN DEPTH OF MANHOLE EXCEEDS 5 FEET.
 4. SEE DETAIL 07000.02 FOR MANHOLE STEP SPECIFICATIONS.



**STANDARD COMBINATION AIR VALVE MANHOLE OFFSET FROM MAIN
(FOR POTABLE WATER SYSTEMS)**

DETAIL No.
06000.15
SHEET 2 OF 2

EFFECTIVE: 12/10/09