



- NOTES:**
1. CONCRETE SHALL BE 3000 P.S.I.
 2. CONCRETE ENCASEMENT NOT REQUIRED WHEN PIPE IS AT LEAST THREE (3) FEET UNDER CENTERLINE OF CREEK BOTTOM.



STANDARD CONCRETE ENCASEMENT FOR STREAM CROSSING

DETAIL No.
07000.14
SHEET 1 OF 1