



- NOTES:**
1. THERE SHALL BE AN 18 INCH VERTICAL SEPARATION BETWEEN WATER AND SEWER LINES WHEN DIRECTLY OVERHEAD.
 2. WATER AND/OR SANITARY SEWER LINES SHALL BE A MINIMUM OF 2 FEET FROM THE EDGE OF THE CURB AND GUTTER.
 3. ENCROACHMENT ONTO TOWN MAINTAINED RIGHT OF WAY SHALL FOLLOW CONDITIONS OF THE APPLICABLE ENCROACHMENT AGREEMENT OR FRANCHISE AGREEMENT.
 4. FOR FIRE HYDRANT LOCATION SEE STD. DETAIL 06000.07.



EFFECTIVE: 01/05/17

STANDARD UTILITY LOCATIONS IN STREET

DETAIL No.
03000.05
SHEET 1 OF 1