


NOTES:

1. FLUSHING DEVICE SHALL HAVE A SELF DRAINING, DOUBLE CHECK VALVE FOR FREEZE PROTECTION.
2. PIPING SHALL BE 2 INCH BRASS OR COPPER TUBING.
3. AREA AROUND FLUSHING DEVICE SHALL BE GRADED TO FACILITATE FLOW AWAY FROM THE SPLASH PLATE.
4. ENTIRE ASSEMBLY SHALL BE LOCATED IN A DEDICATED TOWN OF CARY EASEMENT OR AS DIRECTED.



EFFECTIVE: 01/05/17

STANDARD AUTOMATIC FLUSHING DEVICE

DETAIL No.

06000.20

SHEET 2 OF 2