



- NOTES:**
1. VALVE OPERATING NUT MUST BE EXTENDED SO THAT THE DEPTH IS NO GREATER THAN 8 FEET FROM THE SURFACE USING AN EXTENSION KIT FROM THE VALVE MANUFACTURER.
 2. PRECAST CONCRETE ENCASEMENT IS NOT ALLOWED OUTSIDE OF PAVED AREAS.



EFFECTIVE: 01/05/17

RECLAIMED WATER VALVE BOX INSTALLATION

DETAIL No.
06500.07
SHEET 1 OF 2