



NOTES:

1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 8-FT DEPTH FROM THE SURFACE.
2. SPUR GEAR OPERATOR REQUIRED FOR GATE VALVES ≥ 18 INCHES.



**RESILIENT WEDGE GATE VALVE ASSEMBLY FOR RECLAIMED WATER
(VERTICAL INSTALLATIONS)**

DETAIL No.
06500.08
SHEET 1 OF 3