



**NOTES:**

1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 8-FT DEPTH FROM THE SURFACE.
2. HORIZONTAL GATE VALVES SHALL ONLY BE INSTALLED WHERE VERTICAL ALIGNMENT IS NOT POSSIBLE DUE TO DEPTH, MINIMUM CLEARANCE, OR OTHER CONFLICTS.



**RESILIENT WEDGE GATE VALVE ASSEMBLY FOR RECLAIMED WATER  
(HORIZONTAL INSTALLATIONS)**

DETAIL No.  
**06500.08**  
SHEET 2 OF 3

EFFECTIVE: 01/05/17