



- NOTES:**
1. INSTALLATION TO BE THE SAME AS FOR STANDARD 4 INCH SEWER SERVICE CONNECTION (SHEET 1 OF 4).
 2. ALL 6 INCH SEWER SERVICES MUST GO TO A MANHOLE.
 3. MARKING TAPE SHALL BE INSTALLED FOR ALL SERVICE CONNECTIONS FROM THE MAIN LINE TO THE CLEANOUT FOR ALL NEW CONSTRUCTION OR RETROFIT INSTALLATIONS USING OPEN TRENCH METHODS.



STANDARD SANITARY SEWER SERVICE MANHOLE TAP

DETAIL No.
07000.09
SHEET 3 OF 4