



PROFILE VIEW

SEE SHEET 1 OF 2 FOR
PLAN VIEW

NOTES:

1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE DIRECTOR OF WATER RESOURCES.
2. WET WELLS SHALL BE EPOXY COATED (80 mils).
3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES, AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.
4. PROVIDE LEVERAGE BAR FOR 2 INCH NUT TO BE LEFT IN VALVE VAULT.



EFFECTIVE: 01/05/17

WET WELL AND VALVE VAULT

DETAIL No.

07500.02

SHEET 2 OF 2