



**NOTE:**  
TO ENSURE POSITIVE DRAINAGE, THE VAULT SHALL HAVE AN OPEN BOTTOM TO ALLOW DRAINAGE THROUGH STONE.

DIMENSIONS (INCHES)	
A	B
18 $\frac{3}{4}$ "	30 $\frac{3}{8}$ "

- NOTES:**
- 1) PIPING TO BE 'NO LEAD' BRASS AND COPPER TUBING. METER INLET AND OUTLET TO BE EQUIPPED WITH FLANGED BALL ANGLE METER VALVES.
  - 2) CUSTOM SETTERS SHALL BE EQUIPPED WITH STANDARD LOW BYPASS WITH BALL VALVE AND PADLOCK WINGS.
  - 3) CUSTOM SETTERS SHALL BE AS MANUFACTURED BY MUELLER, FORD, AY MCDONALD, OR APPROVED EQUAL.
  - 4) ALL BRASS COMPONENTS SHALL BE 'NO LEAD' BRASS MEETING UNS C89833 AS PER ASTM B584.
  - 5) ALL COMMERCIAL APPLICATIONS REQUIRE A SEPARATE ABOVE GROUND BACKFLOW PREVENTER.
  - 6) CUSTOM SETTER SHALL BE INSTALLED SUCH THAT METER REGISTER IS LOCATED 5 TO 8 INCHES BELOW METER BOX COVER.



**STANDARD 1 $\frac{1}{2}$ " & 2" METER INSTALLATION & VAULT**

**DETAIL No.**  
06000.02  
SHEET 1 OF 1