



MAXIMUM BRANCH CONNECTIONS	
SUPPLY LINE SIZE (INCHES)	MAXIMUM NUMBER OF BRANCHES
1	1
1.5	2
2	2

- NOTES:**
- 1) THERE SHALL BE NO MULTIPLE CONNECTIONS FROM EXISTING 3/4 INCH SERVICE LINES.
 - 2) METER BOXES SHALL BE AS DESCRIBED IN THE STANDARD SPECIFICATIONS UNDER WATER DISTRIBUTION; METER BOXES SHALL NOT BE LOCATED IN AREAS SUBJECT TO VEHICULAR TRAFFIC.
 - 3) NO LEAD CURB STOP SHALL BE CENTERED ON MULTIPLE BRANCH SERVICE.
 - 4) ALL BRASS COMPONENTS SHALL BE 'NO LEAD' BRASS MEETING UNS C89833 AS PER ASTM B584.

* NO LEAD BRASS TEE OR WYE: INLET SIZE X 1 INCH



EFFECTIVE: 07/01/13

STANDARD MULTIPLE BRANCH SERVICES

DETAIL No.
06000.04
SHEET 1 OF 1