



STANDARD 4' MANHOLE RING AND COVER.  
NOTE: COVER SHOULD BE LABELED WATER.  
(SEE DETAIL 07000.03)

- NOTES:
- 1) ALL SIAMESE CONNECTION'S MUST BE WITHIN 50 FEET OF A FIRE HYDRANT.
  - 2) SIAMESE CONNECTION CAN BE ATTACHED TO BUILDING.



EFFECTIVE: 12/10/09

## CURB SIDE FIRE DEPARTMENT CONNECTION

DETAIL No.  
06000.18  
SHEET 1 OF 2