



- NOTES:**
1. ALL MANHOLE CONNECTIONS SHALL BE PREFABRICATED OR CORED WITH A CONCRETE CORING MACHINE.
  2. ALL MANHOLES SHALL BE VACUUM TESTED.
  3. EXTENDED BASE REQUIRED FOR ALL MANHOLES WITH MORE THAN 12-FT DEPTH OF BURY.
  4. PROVIDE A MINIMUM 0.1 FOOT IN-OUT DROP FOR STRAIGHT RUNS AND 0.2 FOOT IN-OUT DROP FOR ANGLE RUNS.



**STANDARD PRECAST CONCRETE MANHOLE  
6-FT DIAMETER OR LARGER FOR PAVED AREAS**

DETAIL No.  
07000.01  
SHEET 3 OF 3