



- NOTES:**
1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE TOWN ENGINEER.
 2. WET WELLS SHALL BE EPOXY COATED.
 3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES, AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.

SEE SHEET 2 OF 2 FOR PROFILE VIEW



WET WELL AND VALVE VAULT

DETAIL No.
07500.02
SHEET 1 OF 2