



NOTE:
MANHOLE STEPS NOT
SHOWN IN PROFILE.

PROFILE VIEW

SEE SHEET 1 OF 2 FOR
PLAN VIEW

- NOTES:**
1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE TOWN ENGINEER.
 2. WET WELLS SHALL BE EPOXY COATED.
 3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES, AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.



EFFECTIVE: 12/10/09

WET WELL AND VALVE VAULT

DETAIL No.
07500.02
SHEET 2 OF 2