



PLAN VIEW

SEE SHEET 2 OF 2 FOR SECTION "B-B"

SECTION "A-A"

NOTES:

1. THERE SHALL ONLY BE A SINGLE INFLUENT LINE INTO THE GRINDER MANHOLE.
2. GRINDER MANHOLES SHALL BE EPOXY COATED.



EFFECTIVE: 12/10/09

SEWAGE GRINDER UNIT (MANHOLE INSTALLATION)

DETAIL No.

07500.03

SHEET 1 OF 2