

Town of Cary Pump Station Inspection Sheet



Facility Name: Westwood Park PS

Inspection Date: 2/26/2002

ID Number: 026

Drawdown Date:

Pump

Condition: Good

Type: Submersible

Pump One: 55 gpm

Discharge Diameter: 1.25"

Pump Two: 50 gpm

Control: Float / FVNR Starter

Firm Capacity: 50 gpm

Motor Horsepower: 4.7

Design Point (flow): 82 gpm

Pump RPM: 3450

Design Point (pressure): 63 feet of water

Manufacturer: ABS

Rep: Pete Duty & Associates, Inc.

Model: M35

919-245-5070

203-238-2700

Wetwell: 6' Diameter


4.5' Deep

Vol: 1,000 gal

Comments:

-removed from service

Town of Cary Pump Station Inspection Sheet



Westwood Park Pump Station



Control Panel



Odor Control Chemical Containment



Valves



Wetwell



Wetwell

